

EQUIVALENT SOUNDABSORPTION AREA PER OBJECT conform EN-ISO 354:2003




Principal: Buzzispace

Variant 2: BuzziTube XXXL 2500 mm



— 1/3 oct.
* 1/1 oct.



volume reverberation room: 214 m³

number of elements: 1

measured at: Peutz Laboratory for Acoustics

signal: broad-band noise

bandwidth: 1/3 octave

	1,67	2,81	5,88	7,98	8,15	8,15
1/3 oct.	1,80	4,46	6,58	8,27	7,92	8,43
	2,58	5,00	7,20	8,16	8,39	8,60
1/1 oct.	2,02	4,09	6,55	8,14	8,15	8,39

publication is permitted for the entire page only

Mook, measured at 13-10-2022

Absorb, versie 5.9 / 5.10.1 mode 9, PM: JK, file: a4183 E#373-408 F#483-518 A#519 T₁ = 17,2 °C T₂ = 17,1 °C p₁ = 101,4 kPa p₂ = 101,4 kPa h₁ = 55,9 % h₂ = 58,0 %